




## Organic Rankine Cycle

This model represents a simple system for recovering energy from fluid with a poor heat quality. That is they aren't very hot.

A low boiling fluid is used to permit boiling and super heating at reasonable temperatures. The superheated gas is then reduced in pressure in a turbine, recovering energy. The low pressure gas is condensed, typically in an air cooler, and then pumped back up to pressure and introduced into the boiler.

The envelope plot and the lines representing the changes in pressure and temperature at each stage is a valuable tool for trying to get the best result. The turbine line should always be in the vapour phase and the the pump line should always be in liquid region.



cmp	"R245fa;hflow"
HotFluidInT	100 degc
HotFluidOutT	70 degc
PTurbineOut	310 kpa
How much the boiler pressure is below the saturation pressure for super heating	
SuperheatP	20 kpa
ExchQ	1 mW
TurbineEff	0.8

Boiler pressure drop.

ExchDP

50 kpa

TAirCoolOut

40 degc

Air cooler pressure drop

AirCoolerDp


50 kpa

The temperature approach between the heat source fluid and the boiled outlet temperature

HotDt

5 K

Envelope



PExchOut	1109.85 kPa
PExchIn	1159.85 kPa
ColdDt	29.47388 K
TurbinePower	86.30 kW
TM	1500.0

ThermalEff	8.21 %
------------	--------

PumpPower	4.21 kW
-----------	---------

Doesn't account for air cooler fan power
--

PowerOut	82.09 kW
----------	----------

AirCoolerQ	917.91 kW
------------	-----------

Overview

?

Notes

Flash:  
ExchOut

Flash:  
ExchIn

Flash:  
ExchOutPSat

cmp  
R245fa;hflow  
R245fa;hflow

MoleFracs  
1  
1.00000

Flow  
ExchQ / ( ExchOut.h - ExchIn.h )  
122.31 kmol/h

TEchOut  
HotFluidInT - HotDt  
95.00000 degC

envCalc  
ExchOut.envelope  
Table [ 78, 2 ]

HotFluidInT  
100 degC  
100.00000 degC

HotFluidOutT  
70 degC  
70.00000 degC

PTurbineOut  
310 kPa  
310.00 kPa

SuperheatP  
20 kPa  
20.00000 kPa

Notes

ExchQ  
1 mW  
1000.00000 kW

TurbineEff  
0.8  
0.80000

ExchDP  
50 kPa  
50.00 kPa

Notes

TAirCoolOut  
40 degC  
40.00 degC

AirCoolerDp  
50 kPa  
?

Notes

Flash:  
AirCooler

HotDt  
5 K  
5.00 K

Notes

Graph:  
Envelope

PExchOut  
ExchOutPSat.p - Superheat  
1109.85 kPa

PExchIn  
PExchOut + ExchDp  
1159.85 kPa

Model:  
Turbine

Basic expander calculation.

Model:  
Pump

Basic compressor calculation.

ColdDt  
HotFluidOutT - ExchIn.t  
29.47398 K

TurbinePower  
Turbine.Power  
86.30 kW

ThermalEff  
PowerOut/ExchQ  
8.21 %

PumpPower  
Pump.Power  
4.21 kW

PowerOut  
TurbinePower - PumpPower  
82.09 kW

Doesn't account for air cooler fan power

AirCoolerQ  
Turbine.Out.hFlow - AirCooler.hFlow  
917.91 kW